SCG PLATFORM RELEASE NOTES

Release r135

New features and changed features

- 642244 [SCG Portal] Changes in notification headers on the sync page
  - We removed notification when equipment is not connected. Now only indicators are marked in red and indicates that something is wrong.



  - Notification headers are replaced with toast notifications – the same as in other parts of SCG Portal. They will be auto dismissed after 5 seconds.



- 642245 [SCG Portal] Change 'Connected' to 'Sensor connected' on Sync Page

  The text ‘Connected’ was confusing for newer users and could be misinterpreted, we changed that.



- 642251 [SCG Portal] Change styles on Sync Page

  The styling of the Sync Page was not like the rest of the SCG portal, we changed that.

- 642271 [SCG Portal] Change inputs behaviour on Sync Page

  Information about boundaries was moved to a tooltip. The tooltip text will be changed to red when value is incorrect. Steps for increment keys were updated to proper values (1, 0.1 and 20).



- 395829 [OW flow] Circuit of which its sync has not been verified, should not send 'SCG Monitoring Quality warnings'/'SCG system status warnings' (except the 'circuit not yet in sync'-warning)

  The platform produced to many 'SCG Monitoring Quality warnings'/'SCG system status warnings' during the setup of a circuit. Operators and users just want messages which have meaning. When system is not yet marked as synchronized – only the Sync is not yet verified 'SCG Monitoring Quality warnings'/'SCG system status warnings' will be created. This will result in less warnings and more to the point warnings.

Fixes

- 450112 [Circuit list] Filter for new warning icon (exclamation mark) is used only for warning and not faults

  We did not implement the filtering correctly, so we corrected that. The new faults (from last week) are now filtered with new warning option.



- 548368 Download functionality API returns 500 in some negative cases

  Some APIs return an internal error hiding the real error, we corrected that.

- 615294 [Circuit List] Circuit status list API endpoint is returning 500 for some negative cases

  The Circuit status list API returned an internal error in some negative cases, we corrected that.

- 642928 [SCG Portal] Tooltip for circuit name is missing on Warnings list

  The tooltip was missing on the Warnings list. The full circuit name is visible now in the tooltip.



- 646190 [SCG Portal] Max propagation time deviation and Max PD detection sensitivity fields are dependent on Fault Location checkbox

  Some fields in SCG Portal were related to each other, but they should not be related. We corrected that behaviour.

- 639178 Circuit not found gives an Authorization error

  When entering a URL with a specific circuit and the circuit did not exist, the user got a message about authorization which was not reflecting the real problem. The real reason was the circuit did not exist, so we corrected that.



- Various security related issues
- Various efficiency improvements