SCG PLATFORM RELEASE NOTES

Release r125

New features

- **Automated checks in sync portal** The PD detection sensitivity and expected propagation time are now automatically calculated on-the-fly in the sync portal. A green/red light indicates whether they are within or outside expected and allowed limits. With this feature manual calculation and checks of these parameters by the Operator are not needed anymore.

Fixes

- 345999 API endpoint Failure Probability gives Internal Server Error (500) for circuit 23426
- 345274 An xlsx file with an ü or ö in the filename cannot be uploaded as cable circuit components list
- 345277 Using an umlaut in the names of cable circuit components is not possible
- 350880 In cable circuit components upload function it is possible to add branches to other component types than RMU or joints
- 350894 In cable circuit components upload function it is possible to add a negative number of branches
- 351687 A few small typos on the contact edit page
- 352999 Old, no longer valid, operational warnings are cleaned up too late (only after 24 hours)