SCG PLATFORM RELEASE NOTES

Release r139

New features and changed features

- 713451 [SCG Portal] Improved table sorting
    - Updated column header sorting behavior. Previously, clicking a header cycled through three states (ascending, descending, and undefined). The sorting now switches only between ascending and descending, reducing the number of clicks needed to change the table order.



- 716221 [SCG Portal] Clearer classification column name and values in Fault History
    - In the previous release, we introduced the 'Transient Classification' column in the Fault History table. This column has now been renamed to 'Classification' to make it easier to understand.
    - The list now displays the values 'Permanent Fault', 'Intermittent Fault' or 'Fault', making the information easier for users to interpret.



- 722633 CR173 Clearer fault notification message for fault in branching cable
    - Improved the text in the fault notification when a detection occurs near an RMU or in a branching cable. The previous wording could be confusing, so the updated message now provides clearer and more intuitive guidance.



- 718078 [SCG Portal] Event messages
    - In the event message table automated messages are entered by ‘DNV operator’, with this release this will be changed to ‘Operator’ or the name of the person doing it.

- 726650 [SCG Portal] Help page link replacement
    - The Help page in the portal shows a link to a new SCG support page. This page provides downloads and information independent of the SCG version and includes links to version-specific tools and documentation.



- 728716 [SCG Portal] Attention page / Circuit detail page text changes
    - On the Attention page we adjusted some tables titles.

Was	Changed
Fault(s) detected by SCG	Fault circuit condition warnings
SCG warnings due to PD activity	PD circuit condition warnings

    - On the Circuit detail page rename the following titles:

Was	Changed
Detected fault(s)/Rejected signal(s)	PD circuit condition warnings / rejected signals
Active SCG Warnings	Active PD circuit condition warnings

    - The menu item "View SCG warning/fault chart" is changed to "View PD chart"



    - The ‘View PD/SCG warning data chart’-table (which was on the right-side bottom below the ‘Active SCG Warnings’) is removed. The ‘View PD chart’ allows you already an easy way to select a different timeframe.

- 478221 [SCG Portal] In the add Circuit wizard it is now possible to skip step 3 and 4
    - When adding a new Circuit or copying an existing one, users are guided through a multi-step wizard. Previously, Steps 3 (Sensor configuration) and 4 (Cable configuration) were mandatory.

These steps are now optional, enabling users to create large batches of circuits more efficiently when sensor and cable details are not yet known. The information can be added or updated at a later stage.



- 725076 [SCG Portal] Copy from option in the Add circuit wizard now allows searching for circuits and customers
    - When copying an existing circuit in the Add Circuit wizard, users previously had to choose from a long dropdown list without the ability to type or search. This is also fixed for the Customer dropdown list.

      This made it difficult - especially for customers with many circuits - to quickly find the correct one. We've resolved this by enabling text input in the dropdown, allowing users to type part of a circuit name and easily filter the list.



- 713438 [SCG Portal] Contacts list on Organization page
    - Added a new column that displays the warning messages each contact is subscribed to, making subscription details accessible with fewer clicks.



- 717499 [SCG Portal] Show region data as extra column in Organization contacts list
    - Added a new column to the contact list on the Organization page that displays each contact's Region. This is particularly useful for organizations that work with regional groupings. The additional context provides clearer information and reduces the number of clicks needed to find it.



Contact Name	Phone	Fault by SMS	Email	Monthly Summary by Email	Message to receive	Fault by Email	Region	Notes	
[redacted]	[redacted]	✓	[redacted]		Red Operational Warning, PD Warning	✓	AFlowRegion		Delete
[redacted]			[redacted]	✓	Red Operational Warning, Orange Operational Warning, PD Warning	✓	AFlowRegion	test	Delete

Bugs

- Various security related issues
- Various efficiency improvements