SCG PLATFORM RELEASE NOTES

Release r129

Changed features

- Improvements to SCG landing page at https://scg.dnv.com/
    - Faster loading
    - Improved automatic scaling when browser window is resized

Fixes

- 378420 – Auto-sync-in-progress led always stays solid green (even when auto-sync is running)
- 426092 – Incorrect grey area (indicating ‘no measurement performed’) when there are measurements but no PD dots
- 348873 – Number of branches fields are not editable for existing components on the circuit component page
- 407306 – Chinese translations for 'Latest CU connection' and 'Latest pulse file' in Portal sync page are missing
- 396115 – User receives error message when opening sensor detail page with read-only rights
- 392301 – Error when adding circuit in SCG website if user is attached to a distributor group (multiple customers)
- 398342, 398340, 398286, 398274, 398272 – Various security updates